

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212780  
Address: 1921 NE CATALINA AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - R</b>	Khanh Nguyen	Failed	Wednesday, September 08, 2021

Corrective Action Required:

1	Misc	-PROVIDE A CLEANOUT AT SEWER CHANGE OF DIRECTION MORE THAN 45 DEG
---	------	---

**Comments:**