

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212708
Address: 4705 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed	Thursday, September 09, 2021

Corrective Action Required:

1	Misc	INSPECTION DENIED. EROSION CONTROL SHALL BE IN COMPLIANCE. INSTALL EROSION CONTROL ALONG THE STREET. PROVIDE MIN 3/4" GRAVEL AT LOT ENTRANCE
---	------	--

Comments: