

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200773
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Failed	Thursday, September 09, 2021

Corrective Action Required:
1 THE FOLLOWING AREAS ARE APPROVED
-HARD LID AT OR

Corrective Action Required:
2 Miscellaneous Correction
-Cover open J boxes in storage and control rooms
-Label 1 hour fire barrier in corridor and storage max 15' from doorways and max 30' spacing

Comments: