

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20200866
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit	Nick Lightner	Partial	Thursday, September 09, 2021

Informational:

1 Misc

Chlorinating water lines.

9-9-21 9:20. Started Chlorination of 6in line and 8in line at 8:15

10:37 Walked tracer wire on water lines. Tracer wire passed.

Comments: