CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210596

Address: 2102 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Robb Popp Failed Thursday, September

Residential 09, 2021

Corrective Action Required:

1 Miscellaneous -Seal fire blocking above fireplace-SEAL GAPS

Correction -Provide LUS24 hangers per truss plans at M3 trusses-MASTER BATH WC

-Provide solid blocking at sheathing break & nail per code left of kitchen

window-BOT COMPLETE

-Nail exterior wall sheathing corner at kitchen sink & bed #1 near window & dining = throughout-DINING NOT DONE, KITCHEN/BED ONE NAILS NOT IN FRAMING, GARAGE INCOMPLETE, ETC.-SEE PLANS FOR ALL BRACED WALL

LOCATIONS AND COMPLETE NAILING PATTERN

-Provide min 4 studs below each girder truss bearing point per roof

plan-GARAGE WALL

-Strap cut top plate bed #2 interior load bearing wall -BOTH SIDES

-Seal exterior penetrations bed #3 closet

-Complete pyro-guard to top plate bed #3, at HVAC line set & garage-NOT

COMPLETE

Comments: