CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20212561

Address: 940 NW PRYOR RD, Unit:C, LEES SUMMIT, MO 64081

Inspected On: Thursday, September 09, 2021

Inspected By: Michael Harkins Expiration Date: 09/29/2021

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Michael Harkins Temporary C of O Thursday,

Codes Commercial September 09,

2021

Corrective Action Required:

1 Misc Provide insulation for drains under men's & women's restroom

vanity's

Provide missing cover panels @ service panels