

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210252
Address: 138 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Passed	Friday, September 10, 2021

Informational:
1 Misc Forms were placed and aggregate was present and compacted. Need to clean the roadway before pouring. RP 9-7-21

Informational:
2 Misc Finished sidewalk meets LS and ADA specs. RP 9-10-21

Comments: