

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201796
Address: 2309 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, September 10, 2021

Corrective Action Required:

1	Misc	REVISED PLOT PLAN REQUIRED BEFORE C OF O FOR DECK THAT HAS BEEN EXPANDED FROM APPROVED PLANS, DECK INCOMPLETE AT ROUGH INSPECTION, DECK PIERS POURED WITHOUT INSPECTION, ENGINEER REPORT REQUIRED
---	------	---

Comments: