

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211772
Address: 314 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, September 10, 2021

Corrective Action Required:

1	Miscellaneous Correction	: PFH PORTAL FRAMING ONLY : CITY APPROVED PLANS SHOW PFH @ SINGLE GARAGE DOOR ALSO, PLANS ON SITE DID NOT HAVE PAGE A4.0 WITH THIS DETAIL : POST ADDRESS :
---	--------------------------	--

Comments: