

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210580
Address: 711 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Friday, September 10, 2021

Informational:

1	Misc	OK to rock exterior walls Ok to rock storage walls
---	------	---

Corrective Action Required:

2	Misc	-Provide bocca plate at dwv in bathroom bottom track -Protection plate at electrical in bathroom bottom track -Provide grommets at pex lines through studs
---	------	--

Comments: