

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212682
Address: 1841 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Friday, September 10, 2021

Corrective Action Required:

1	Misc	MAINTAIN EROSION CONTROL ON LOT. SILT FENCE REQUIRES CONTINUOUS MAINTENANCE. CLEAN ALL MUD AND GRAVEL THAT HAS WASHED OVER SILT FENCE ONTO STREET AND WALK. CLEAN MUD BUILDUP AT FRONT OF GUTTER BUDDY AT STORM INLET FRONT OF LOT
---	------	--

Comments: