

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210156
Address: 2042 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Partial	Friday, September 10, 2021

Informational:		
1	Misc	Forms were placed and aggregate was present and compacted. ADA Ramp is located just east of the driveway and wasn't shown on the plot plan. RP 8-2-21
Corrective Action Required:		
2	Misc	Wrong concrete was used for the sidewalk. Needs to be removed and replaced with 4K KCMMB mix. RP 8-6-21
Informational:		
3	Misc	They removed the wrong concrete. Forms were placed and aggregate was present and compacted for the new sidewalk. RP 9-10-21

Comments: