

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213746
Address: 725 SW 15TH CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Monday, September 13, 2021

Corrective Action Required:

1	Misc	INSPECTION DENIED
---	------	-------------------

NO EROSION CONTROL PRESENT AT TIME OF INSPECTION 10:57 AM

PROVIDE EROSION CONTROL AROUND PERIMETER OF LOT, PROTECT CREEK AND POND

CLEAN MUD BUILDUP FROM FRONT OF GUTTER BUDDY AT FRONT OF LOT

Comments: