



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20213043, Public Works Right of Way Permit
Address: 1721 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Matt Munger	Passed	Monday, September 13, 2021

Corrective Action Required

1 Misc

Site Visit - The service line has been installed. The yard on either side of the street was not established prior to Spires work. Spire did mark depths going under the street but they did not meet the required 36" under the road way, but it does not appear the street was not affected by the depth of the bore at this time. Notating for any future issues. I will also attach pictures.

Comments: