

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210296
Address: 119 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Michael Harkins	Failed	Monday, September 13, 2021

Corrective Action Required:

1	Misc	-Erosion control requires continuous maintenance. Repair damaged sections within 48 hours -immediate street cleanup required -Remove debris from storm water inlet -provide and maintain gravel filter -no further inspections until issues are resolved
---	------	--

Corrective Action Required:

2	Misc	-Erosion control requires continuous maintenance. Repair damaged sections within 48 hours -immediate street cleanup required -Remove debris from storm water inlet -provide and maintain gravel filter -no further inspections until issues are resolved
---	------	--

Corrective Action Required:

3	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. - MAINTAIN SILT FENCE UNTIL SOD COMPLETE - - CLEAN STREET - - REMOVE SEDIMENT BUILD UP AT GUTTER BUDDY CURB INLET -
---	---------------------------------------	--

Corrective Action Required:

4	DCM6 ESC INSP	STREET CLEAN UP REQUIRED IMMEDIATELY, AND SHALL BE COMPLETED
---	---------------	--

DENIED STREET
CLEAN UP

PRIOR TO REQUESTED INSPECTION(S) BEING PERFORMED.

Comments: