CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20210296

Address: 119 NW JOSHUA DR, LEES SUMMIT, MO 64081

Inspected On: Monday, September 13, 2021

Inspected By: Michael Harkins

Expiration Date: 9/29/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - Michael Harkins Temporary C of O Monday,

Codes Residential September 13,

2021

Corrective Action Required:

1 Miscellaneous OBTAIN LAWN IRRIGATION PERMIT & submit back flow certification

Correction Submit as graded plot plan for review

Remove sediment buildup at gutter buddy curb inlet

Clean street

Land sewer tracer wire in a box at grade