

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20210481

Address: 2550 SW 3RD ST, LEES SUMMIT, MO 64081141 NW MORTON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Ronald Paynter	Passed	Monday, September 13, 2021

Informational:

1 Misc

Randy Spalding had a tandem dump truck with a 19.22 ton load. The curb line passed the proof roll. RP 8-16-21

Informational:

2 Misc

They had a tandem dump truck with a 20.6 ton load. No issues with the proof roll. RP 9-13-21

Comments: