

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211044
Address: 218 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Monday, September 13, 2021

Corrective Action Required:

1	Miscellaneous Correction	: PFH GARAGE PORTAL FRAMING ONLY : TIGHTEN 5/8 ANCHOR BOLTS PROVIDE SOLID BLOCKING AT SHEATHING BREAKS ABOVE DOOR AND NAIL PER CODE FASTEN TOP PLATE TO HEADER WITH TWO ROWS 16D SINKER AT 3' O.C. PER PLAN DETAIL 1 SHEET S4.0
---	--------------------------	---

Comments: