

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211575
Address: 131 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, September 14, 2021

Corrective Action Required:

1	Miscellaneous Correction	: PFH GARAGE PORTAL FRAME ONLY : Nail exterior wall sheathing @ king and jack stud to header per plan 3" OC with 8d common nails PFH detail 12 sheet S2.0
---	--------------------------	---

Comments: