

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210533
Address: 838 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Partial	Tuesday, September 14, 2021

Corrective Action Required:

1	Misc	: PLUMBING ONLY : - PROVIDE 16 GAGE SHIELD PLATES @ DWV SUCH PLATES SHALL COVER THE AREA OF THE PIPE WHERE THE MEMBER IS NOTCHED OR BORED AND SHALL EXTEND NOT LESS THAN 2" ABOVE SOLE PLATE AND BELOW TOP PLATES (2018 IPC 305.6) - PROVIDE MIDPOINT SUPPORT VERTICAL DWV 2" & SMALLER (2018 IPC TABLE 308.5b) - PRESSURE STEADY AT 5 PSI -
---	------	--

Comments: