CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRRES20210149
Address:	2104 NW SHAMROCK AVE, LEES SUMMIT, MO 64081
Inspected On:	Tuesday, September 14, 2021
Inspected By:	Michael Harkins
Expiration Date:	10/13/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Tuesday, September 14, 2021

Corrective Action Required:

1 Miscellaneous PAY OUTSTANDING FEES Correction LOWER WATER METER PIT LID TO GRADE, 14" TO 18" TOP OF METER TO LID