

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213746
Address: 725 SW 15TH CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 14, 2021

Corrective Action Required:

1	Misc	-add/raise chairs on rebar throughout where rebar doesn't have req clearance to soil -remove soil at jumps where rebar doesn't have req clearance to soil -clean all loose soil/rocks from footing at rear
---	------	--

Comments: