

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204751
Address: 2017 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|----------------------------------|
| Occupancy Inspection - Codes Residential | Khanh Nguyen | Failed | Wednesday, September 15, 2021 |

Corrective Action Required:

| | | |
|---|-----------------------------|---|
| 1 | Miscellaneous Correction | -Sidewalk inspection pending -No deck pier inspection on record for covered deck (revised plan calls for pier L to be 28" diameter x 36" depth measured 18" diameter last week before patio slab poured) |
|---|-----------------------------|---|

Comments: