

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210696  
Address: 2053 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Wednesday, September 15, 2021

Corrective Action Required:

1	Misc	-Walls with fire separation distance less than 5 ft shall be rated 1 hour on both sides-PYRO GAURD REQUIRED TO BE TO TOP PLATE AND NAILED PER CODE
---	------	--

Comments: