CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20211895Address:4733 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
All Rough Inspection - Residential		Khanh Nguyen	Failed	Thursday, September 16, 2021
Corrective Action Required: 1 Misc -Protect plumbing at master bathroom			er bathroom wall top plates	; install strap
	-	-Have engineer ok the ridge I beam, in place of the 24" lvl		
	-	-Lower supply duct to ceiling level at both basement bathrooms		
	-	o basement bathroom wall from fur down ceiling space		

Comments: