

## ANALYTICAL REPORT

September 09, 2021

Work Order: 1EI0631

Page 1 of 3

Report To
Diana Johnson City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 09/08/2021 12:23PM Collector: Salinas, Daniel Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Redford Construction

Project Number: Hook Farms

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
<b>1EI0631-01</b>	Cul de Sac Blow Off			Matrix:Drink Wtr		Collected: 09/08/21 11:07	
Total Coliforms	<1.0 MPN/100ml	1.0	1EI0338	9223B-QT	CLJ	09/08/21 16:40	
E. Coli	<1.0 MPN/100ml	1.0	1EI0338	9223B-QT	CLJ	09/08/21 16:40	
<b>1EI0631-02</b>	Middle Blow Off			Matrix:Drink Wtr		Collected: 09/08/21 11:00	
Total Coliforms	<1.0 MPN/100ml	1.0	1EI0338	9223B-QT	CLJ	09/08/21 16:40	
E. Coli	<1.0 MPN/100ml	1.0	1EI0338	9223B-QT	CLJ	09/08/21 16:40	
<b>1EI0631-03</b>	Tie In Blow Off			Matrix:Drink Wtr		Collected: 09/08/21 11:06	
Total Coliforms	<1.0 MPN/100ml	1.0	1EI0338	9223B-QT	CLJ	09/08/21 16:40	
E. Coli	<1.0 MPN/100ml	1.0	1EI0338	9223B-QT	CLJ	09/08/21 16:40	

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.*

City of Lee's Summit - Public Works Dept.  
220 SE Green Str  
Lees Summit, MO 64063

September 09, 2021

Page 2 of 3

Work Order: 1EI0631

**Certified Analyses included in this Report**

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

  

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2022
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2021
MO-KC	Missouri Department of Natural Resources	140	04/30/2022
SIA1X	Iowa Department of Natural Resources	95	02/01/2021

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson  
Project Manager

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.*

**CHAIN OF CUSTODY RECORD**



LABORATORIES, INC.

- 600 E. 17th St. S. Newton, IA 50208  
Phone: 641-792-8451 Fax: 641-792-7989
- 3012 Ansborough Ave. Waterloo, IA 50701  
Phone: 319-235-4440 Fax: 319-235-2480
- 835 S St Paul Kansas City, KS 66105  
Phone: 913-321-7856 Fax: 913-831-6778
- 205 E VanBuren St Centerville, IA 52544  
Phone: 641-437-7023 Fax: 641-437-7040

PAGE \_\_\_\_\_ OF \_\_\_\_\_

**PRINT OR TYPE INFORMATION BELOW**  
**SAMPLER:** Daniel Salinas  
**SITE NAME:** Hook Farms  
**ADDRESS:** Hook Rd & Fryer Rd  
**CITY/ST/ZIP:** Lees Summit, Mo.  
**PHONE:** \_\_\_\_\_

**REPORT TO:**  
**NAME:** Lees Summit / Redford Co.  
**COMPANY NAME:** \_\_\_\_\_  
**ADDRESS:** \_\_\_\_\_  
**CITY/ST/ZIP:** \_\_\_\_\_  
**PHONE:** \_\_\_\_\_  
**FAX:** \_\_\_\_\_

**BILL TO:**  
**NAME:** Redford Co.  
**COMPANY NAME:** \_\_\_\_\_  
**ADDRESS:** \_\_\_\_\_  
**CITY/ST/ZIP:** \_\_\_\_\_  
**PHONE:** \_\_\_\_\_  
**Keystone Quote No:** \_\_\_\_\_  
 (If Applicable)

CLIENT SAMPLE NUMBER	DATE	TIME	SAMPLE LOCATION	NO. OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED	
#1	9-8-21	8:06a	Ful de Sec Blow off	1			Total Coliform	
#2	9-8-21	8:19a	Middle Blow off	1			Total Coliform	
#3	9-8-21	8:27a	in Blow off	1		X	Total Coliform	

**LAB USE ONLY**  
**LABORATORY WORK ORDER NO.** JEI0631  
**SAMPLE TEMPERATURE UPON RECEIPT:** 21°C  
**SAMPLE CONDITION/COMMENTS**  
**LABORATORY SAMPLE NUMBER** JEI0631-01

Relinquished by: (Signature) *[Signature]* Date: 9-8-21 Time: 10:00am  
 Received by: (Signature) *[Signature]* Date: 9/8/21 Time: 10:00am  
 Relinquished by: (Signature) *[Signature]* Date: 9-8-21 Time: 12:23  
 Received for Lab by: (Signature) *[Signature]* Date: 09/08/21 Time: 12:23

Turn-Around:  Standard  Rush  
 Remarks: \_\_\_\_\_  
 Contact Lab Prior to Submission