

ANALYTICAL REPORT

September 08, 2021

Work Order: 1EI0527

Page 1 of 3

Report To
Diana Johnson City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 09/07/2021 10:57AM Collector: Salinas, Daniel Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Redford Construction

Project Number: Hook Farms

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1EI0527-01	Cul de Sac Blow Off			Matrix:Drink Wtr		Collected: 09/07/21 08:04	
Total Coliforms	<1.0 MPN/100ml	1.0	1EI0279	9223B-QT	CLJ	09/07/21 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1EI0279	9223B-QT	CLJ	09/07/21 16:45	
1EI0527-02	Middle Blow Off			Matrix:Drink Wtr		Collected: 09/07/21 08:12	
Total Coliforms	<1.0 MPN/100ml	1.0	1EI0279	9223B-QT	CLJ	09/07/21 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1EI0279	9223B-QT	CLJ	09/07/21 16:45	
1EI0527-03	Tie In Blow Off			Matrix:Drink Wtr		Collected: 09/07/21 08:18	
Total Coliforms	<1.0 MPN/100ml	1.0	1EI0279	9223B-QT	CLJ	09/07/21 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1EI0279	9223B-QT	CLJ	09/07/21 16:45	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

September 08, 2021

Page 2 of 3

Work Order: 1EI0527

Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2022
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2021
MO-KC	Missouri Department of Natural Resources	140	04/30/2022
SIA1X	Iowa Department of Natural Resources	95	02/01/2021

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson
Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

