

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204900  
Address: 1460 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Fire Line - Hydrostatic Test</b>	Joe Starlin	Partial	Thursday, September 16, 2021

Informational:  
1 Misc 6" Private Water Line extension was tested @ 200psi for 2hrs starting at 10:05AM to 12:05AM.  
Hydrostatic test passed.

**Comments:**