

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210367
Address: 2108 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Michael Harkins	Failed	Thursday, September 16, 2021

Corrective Action Required:

1	Misc	PROVIDE MINIMUM 10 PSI FOR 15 MIN
---	------	-----------------------------------

Corrective Action Required:

2	Miscellaneous Correction	PROVIDE GUAGE WITH MINIMUM 10 PSI FOR 15 MINUTES FOR GAS SERVICE INSPECTION
---	--------------------------	---

Comments: