## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20203580Address:3117 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Patrick Schonfeldt	Partial	Thursday, September 16, 2021

Informational:

1 Misc

PARTIAL ON COPPER FROM TAP TO END OF 10' TAIL, DOUBLE CHECK METER TO LID HEIGHT AT REINSPECT

Comments: