

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210596
Address: 2102 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Thursday, September 16, 2021

Corrective Action Required:

1	Miscellaneous Correction	-Provide solid blocking at sheathing break & nail per code left of kitchen window-BOT COMPLETE -Nail exterior wall sheathing corner at kitchen sink & bed #1 near window & dining = 'throughout-DINING NOT DONE, KITCHEN/BED ONE NAILS NOT IN FRAMING,GARAGE INCOMPLETE, ETC.-SEE PLANS FOR ALL BRACED WALL LOCATIONS AND COMPLETE NAILING PATTERN
---	--------------------------	---

Comments: