

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20210833  
Address: 940 NW PRYOR RD, Unit:H, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Michael Harkins	Failed	Friday, September 17, 2021

Corrective Action Required:  
1 THE FOLLOWING AREAS ARE APPROVED - HARD LID IN RECEPTION AREA, OK TO COVER -

Corrective Action Required:  
2 Miscellaneous Correction FIRE CAULK PENETRATIONS IN SOUTH 1 HOUR WALL  
SUPPORT MC CABLE & LOW VOLT FIRE ALARM

**Comments:**