

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204535
Address: 2029 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Partial	Friday, September 17, 2021

Corrective Action Required:

1	Misc	No aggregate in place
---	------	-----------------------

Informational:

2	Misc	Forms were placed and aggregate was present and compacted. Notified Summit Homes about broken mailbox pad. RP 9-17-21
---	------	---

Comments: