

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210882  
Address: 202 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Ronald Paynter	Partial	Friday, September 17, 2021

Corrective Action Required:

1	Misc	Aggregate was no compacted.
---	------	-----------------------------

Informational:

2	Misc	Forms were placed and aggregate was present and compacted. RP 9-17-21
---	------	---

**Comments:**