

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210882
Address: 202 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Passed	Friday, September 17, 2021

Informational:	
1 Misc	Forms were placed and aggregate was present and compacted. RP 9-10-21
Informational:	
2 Misc	Finished driveway meets LS and ADA specs. RP 9-17-21

Comments: