

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210753
Address: 213 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, September 17, 2021

Informational:	
1 Misc	GARAGE PORTAL FRAME-exterior only ok
Corrective Action Required:	
3 Miscellaneous Correction	3rd party inspection suspended slab ? Secure fireplace Nail joist hanger dining area Seal pan off at dead space master closet Provide BP 1 blocking per joist layout Fire Block dead spaces family room basement Anchor bolts middle 1/3 the width of plate basement Seal gas line above window bed # 4 Fire block (insulate) DWV in dead space bed #4 near furnace Seal fire block dead space at shower basement

Comments: