CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213199 Address: 1153 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspecti	ion:	Inspector:	Outcome:	Date:	
In-wall	Inspection	Khanh Nguyen	Failed	Friday, September 17, 2021	
Correcti	ve Action Required:				
1	Misc -Complete door exits per plan				
		Make sure all circuits serving			
		the patient care area shall meet requirements of NEC517.13, including the switch circuits to lights			
		-Secure 2" and smalle	Secure 2" and smaller PVC at mid-wall height		
		extra 2" of protection	Protect all DVW at bottom and top wall tracks with BOCA plates that provide extra 2" of protection beyond the wall tracks		
		-Install blockings for r	nstall blockings for restroom grab bars		

Comments: