

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210103
Address: 2100 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Adam Nacke	Partial	Friday, September 17, 2021

Informational:
1 Misc 1/20/21 Wednesday
Contractor has installed silt erosion control fence where feasible. The Eastern and the Southern Boundary of project have fencing. Contractor will install additional fencing as plan as needed.

Informational:
2 Misc Informed contractor to fix erosion issue on the east side of property. Also DNR was on site to address the issue.

Comments: