

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204069
Address: 3222 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|----------------------------|
| Occupancy Inspection - Codes Residential | Mark Harding | Failed | Friday, September 17, 2021 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Final sidewalk and driveway inspections required -not approved -obtain lawn irrigation system permit - not paid for -Guardrail at front porch, more than 30" from grade , bring grade up to less than 30" at 36" out from porch, |
|---|------|---|

****OK FOR TCO - TCO EXPIRES 10/8/21****

Comments: