

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211577  
Address: 4420 SW TANZANITE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, September 21, 2021

Informational:

1 Misc -GARAGE PORTAL EXTERIOR OK

Corrective Action Required:

2 Misc  
-All truss hangers per plans  
-Nail triple girder truss together per plans  
-strap plates- Dbl top plate requires 24" offset between plate breaks- see master bed exterior wall at bath wall  
-Nail all exterior sheathing per plans - see east and rear side of house

Comments: