

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210628  
Address: 2106 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Robb Popp	Failed	Tuesday, September 21, 2021

Corrective Action Required:

1	Misc	*9-21-21 -MAINTAIN GRAVEL FILTER, CLEAN DEBRIS FROM STORM INLET, RESTORE SILT FENCE AT PERIMETER BEFORE ANY FURTHER INSPECTIONS
---	------	--

**Comments:**