

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210596  
Address: 2102 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, September 21, 2021

Corrective Action Required:

1	Miscellaneous Correction	-Nail exterior wall sheathing corner at kitchen sink & bed #1 near window & dining **Please nail exterior wall sheathing to sill plates throughout w/ 8d@6" oc  **OK TO ROCK
---	--------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**