

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204900  
Address: 1460 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	Mark Harding	Partial	Tuesday, September 21, 2021

Corrective Action Required:

1	Misc	WELD LIGHT TEST 2 HOODS OK.
---	------	-----------------------------

APPROVED FOR 1ST LAYER TO BE INSTALLED.  
CALL WHEN REEADY

**Comments:**