

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211915
Address: 2366 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 21, 2021

Corrective Action Required:

1	Misc	SHUTOFF REQUIRED AT FUTURE PATIO GAS, SEAL ENDS OF PIPE TO PREVENT CONCRETE FROM ENTERING
---	------	---

Comments: