

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211296
Address: 3118 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 21, 2021

Corrective Action Required:

1	Misc	BASEMENT SLAB POURED WITHOUT INSPECTION OF UNDERSLAB PLUMBING, DYE TEST REQUIRED TO BE PERFORMED BEFORE ALL ROUGH REINSPECT
---	------	---

Comments: