

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210696
Address: 2053 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, September 22, 2021

Corrective Action Required:

1 Misc

****9-22-21**

Inspection denied due to lack of erosion control-Maintain gravel filter, silt fence at perimeter and clean trash and debris from site before further inspections

-Walls with fire separation distance less than 5 ft shall be rated 1 hour on both

sides-PYRO GAURD REQUIRED TO BE TO TOP PLATE AND NAILED PER CODE

Comments: