

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210753
Address: 213 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Wednesday, September 22, 2021

Informational:	
1 Misc	GARAGE PORTAL FRAME-exterior only ok
Corrective Action Required:	
2 Miscellaneous	Secure fireplace
Correction	Nail joist hanger dining area
	Fire Block dead spaces family room basement
	Seal gas line above window bed # 4
	Seal fire block dead space at shower basement

Comments: