

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212708  
Address: 4705 NE FREEHOLD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Residential</b>	Khanh Nguyen	Passed	Wednesday, September 22, 2021

Corrective Action Required:

1	Misc	INSPECTION DENIED. EROSION CONTROL SHALL BE IN COMPLIANCE. INSTALL EROSION CONTROL ALONG THE STREET. PROVIDE MIN 3/4" GRAVEL AT LOT ENTRANCE
---	------	--

Comments: