

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210592  
Address: 134 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Adam Nacke	Partial	Thursday, September 23, 2021

Informational:  
1 Misc Forms are in places and aggregate is present and compacted. Had worker adjust the form to reach the 1.5% slope. Ready to concrete

**Comments:**