CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204900

Address: 1460 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground Electrical Michael Harkins Partial Thursday, September

Inspection - Commercial 23, 2021

Informational:

1 Misc - THE FOLOWING ITEMS ARE APPROVED -

- TRANSFORMER TO BLDG NORTH SIDE -

- CONDUIT FOR LIGHT POLE BASES FRONT SIDE OF BLDG ONLY OK TO COVER -

Comments: